



Code Requirements for WOODWORKING SHOPS

- ✓ Sprinkler system required if building has more than 2,500 square feet of floor area.
- ✓ All machines must have a dust collection system. (Not more than 3 machines).
- ✓ No more than 3 portable dust collectors.
- ✓ Area dust collection system.

General

Applies to all Commercial Uses

- ✓ One fire extinguisher for each 3,000 square feet of floor area (type 2A-10BC)
- ✓ Male and female handicap accessible restrooms required in some cases.
- ✓ “No Smoking” signs posted in public and working areas.
- ✓ Electrical panel circuits labeled.
- ✓ Building address or suite number at front and back (minimum of 6” in height).
- ✓ Permits required for any remodeling (except paint and carpet).
- ✓ Paved parking and drives.
- ✓ Two exits and fire rated corridors if occupant load exceeds 50.
- ✓ Emergency lighting (battery powered) if occupant load exceeds 50.
- ✓ Full handicap accessibility (some exceptions apply).
- ✓ Permits required for new signs.