



NOTE:
 WHERE THE MANHOLE TO ABANDONED IS LOCATED WITHIN A PAVED STREET, THE PAVED STREET IS TO BE SAWCUT AND PREPARED AS A STANDARD STREET CUT REPAIR.

NOTE:
 DETAIL SUBJECT TO CHANGE PER DIRECTION OF CITY OF LEWISVILLE ENGINEERING DIVISION.

*** MANHOLE NOTES**

MANHOLE NOTES:

1. ALL SANITARY SEWER MANHOLES FOR SEWERS LARGER THAN 12" DIA. SHALL BE SPRAYED WITH THE FOLLOWING CORROSION RESISTANT COATING: RAVEN 405-100% SOLDS SOLVENT FREE ULTRA HIGH-BUILD EPOXY SYSTEM FROM RAVEN LINING SYSTEMS WITH A MINIMUM THICKNESS OF 125 MILS.
2. ALL MANHOLES SHALL BE PRECAST NO CAST-IN-PLACE MANHOLES WILL BE ACCEPTED.

Standard Details
 Manhole Abandonment Detail

Revisions:		
No.	Description	Date

Engineering Department

Office No. 972-219-3490

www.cityoflewisville.com

Dated: 4-27-10
 Dated: 09-09-2019

Sheet: 7.8

