



PLAN VIEW

NOTES:

1. CONCRETE – MINIMUM COMPRESSIVE STRENGTH, 4000 PSI @ 28 DAYS
2. REINFORCING STEEL SHALL BE NEW BILLET STEEL CONFORMING TO THE REQUIREMENTS OF ASTM A-615-GR.60.
3. MORTAR SHALL BE TYPE "S"
4. CONSTRUCTION SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF THE "RECOMMENDED PRACTICE FOR ENGINEERED BRICK MASONRY" BRICK OF AMERICA

NOTE:
 ANY SCREENING WALL REQUIRED BY THE GENERAL DEVELOPMENT ORDINANCE SHALL BE CONSTRUCTED AND ACCEPTED PRIOR TO THE ISSUANCE OF ANY BUILDING PERMITS. THE COST OF THE SCREENING WALL CANNOT BE ESCROWED UNDER THE PERFORMANCE ESCROW POLICY AS PART OF THE PUBLIC IMPROVEMENTS.

NOTE:
 DETAIL SUBJECT TO CHANGE PER DIRECTION OF CITY OF LEWISVILLE ENGINEERING DIVISION.



Standard Details

Thin Wall Mow Strip Detail

Revisions:

No.	Description	Date

Department of
 Community
 Development

Office No. 972-219-3490
 Fax No. 972-219-3487
 www.cityoflewisville.com

Dated: 4-27-10

Sheet:
 6.4