



- 1. GATE VALVE
- 2. METER
- 3. DISMANTLING JOINT
- 4. CHECK VALVE
- 5. GATE VALVE
- 6. SUMP HOLE 12" DIAMETER BY 12" DEEP
- 7. SUMP HOLE 12" DIAMETER BY 18" DEEP
- 8. QUAZITE TRAFFIC SIGNAL CABINET BASE 39 3/8"WX27 5/8"DX18" H PART NUMBER PH2436AA.
- 9. ELECTRICAL SERVICE SUPPORT PEDESTAL SERVICE TYPE PS.
- 10. ELECTRICAL SERVICE CONDUIT
- 11. USF FABRICATION INC. THD MINIMUM 60"X72" CUSTOM ALUMINUM DOORS OR EQUAL.
- 12. 72" MINIMUM
- 13. 60" MINIMUM
- 14. 48" MINIMUM
- 15. 48" MINIMUM
- 16. 24" MINIMUM

CASTLE HILLS 20" METER SPEC. PG. 2 OF 3  
 NON-ENGINEERED DRAWINGS  
 NOT TO SCALE

NOTE:  
 DETAIL SUBJECT TO CHANGE PER DIRECTION  
 OF CITY OF LEWISVILLE ENGINEERING DIVISION



**Standard Details**  
 Castle Hills 20" Meter  
 Parts

Revisions:		
No.	Description	Date

Department of  
 Community  
 Development

Office No. 972-219-3490  
 Fax No. 972-219-3487  
 www.cityoflewisville.com

Dated: 9-15-08

Sheet:  
**10.3b**