



- 1. GATE VALVE
- 2. METER
- 3. DISMANTLING JOINT
- 4. CHECK VALVE
- 5. GATE VALVE
- 6. SUMP HOLE 12" DIAMETER BY 12" DEEP
- 7. SUMP HOLE 12" DIAMETER BY 18" DEEP
- 8. QUAZITE TRAFFIC SIGNAL CABINET BASE 39 3/8"W X 27 5/8"D X 18"H PART NUMBER PH2436AA
- 9. ELECTRICAL SERVICE SUPPORT PEDESTAL SERVICE TYPE PS
- 10. ELECTRICAL SERVICE CONDUIT
- 11. USF FABRICATION INC. THD MINIMUM 60"x72" CUSTOM ALUMINUM ACCESSS DOORS OR EQUAL
- 12. 72" MINIMUM
- 13. 60" MINIMUM
- 14. 36" MINIMUM
- 15. 36" MINIMUM
- 16. 24" MINIMUM

CASTLE HILLS 16" METER SPEC. PG. 2 OF 3
 NON-ENGINEERED DRAWINGS
 NOT TO SCALE

NOTE:
 DETAIL SUBJECT TO CHANGE PER DIRECTION
 OF CITY OF LEWISVILLE ENGINEERING DIVISION

Revisions:

No.	Description	Date