



- 1. 5' MINIMUM CLEARANCE BETWEEN METER VAULT AND ELECTRICAL SERVICE SUPPORT PEDESTAL.
- 2. METER VAULT
- 3. QUAZITE TRAFFIC SIGNAL CABINET BASE 39 3/8" W X 27 5/8" D X 18" H PART NUMBER PH2436AA.
- 4. NAZTEC, INC, NEMA M30 BASE MOUNT NEMA CABINET ENCLOSURE, NO SHELVES, INCLUDES POWER PANEL, BLANK PANEL, ANTENNA MOUNTING HARDWARE, FAN/LIGHT PANEL-#2 CORBIN LOCK, NO POLICE DOOR.
- 5. ELECTRICAL SERVICE SUPPORT PEDESTAL SERVICE TYPE PS.
- 6. TESCO SERVICE PEDESTAL MODEL 26-00 FOR ITEMS 5 & 6, USE TXDOT STANDARD PLAN FOR ELECTRICAL DETAILS ELECTRICAL SERVICE SUPPORT PEDESTAL SERVICE TYPE PS ED (8) - 03
- 7. CONDUIT FOR ELECTRICAL SERVICE LINE.
- 8. CONDUIT FOR ELECTRICAL SERVICE LOAD.
- 9. CONDUIT FOR POWER AND COMMUNICATIONS TO VAULT.
- 10. METER VAULT 4" ABOVE GRADE.

CASTLE HILLS 12" METER SPEC. PG. 3 OF 3
 NON-ENGINEERED DRAWINGS
 NOT TO SCALE

NOTE:
 DETAIL SUBJECT TO CHANGE PER DIRECTION
 OF CITY OF LEWISVILLE ENGINEERING DIVISION



Standard Details
 Castle Hills 12" Meter
 Vault Assembly

Revisions:		
No.	Description	Date

Engineering
 Department
 Office No. 972-219-3490
 www.cityoflewisville.com

Dated: 9-15-08
 Dated: 10-28-19
 Sheet:
 10.1c