



- 1. 24" MINIMUM CLEARANCE BETWEEN ANY APPURTENCES AND VERTICAL METER VAULT WALL
- 2. GATE VALVE
- 3. CHECK VALVE
- 4. DISMANTLING JOINT
- 5. PROSONIC FLOW TRANSIT-TIME METER
- 6. USF FABRICATION INC. THD 48" X 72" ALUMINUM ACCESS DOORS OR EQUAL
- 7. QUAZITE TRAFFIC SIGNAL CABINET BASE 39 3/8"W X 27 5/8"D X 18" H PART NUMBER PH2436AA
- 8. REINFORCE CONCRETE PEDESTAL FOR ELECTRICAL SERVOCE
- 9. 5' MINIMUM CLEARANCE BETWEEN POWER PEDESTAL AND METER VAULT
- 10. 12" DIAMETER BY 18" DEEP SUMP PUMP HOLE.
- 11. WATER TIGHT LINK SEAL OR APPROVED EQUAL.
- 12. CONDUIT FOR POWER LINE FEED
- 13. 12" DIAMETER BY 24" DEEP SUMP PUMP HOLE.

CASTLE HILLS 12" METER SPEC.
NON-ENGINEERED DRAWINGS
NOT TO SCALE

NOTE:
DETAIL SUBJECT TO CHANGE PER DIRECTION
OF CITY OF LEWISVILLE ENGINEERING DIVISION



Standard Details

Castle Hills 12" Meter
Vault Assembly

| Revisions: | | |
|------------|-------------|------|
| No. | Description | Date |
| | | |
| | | |
| | | |
| | | |
| | | |

| | |
|---|---|
| Department of Community Development | Dated: 9-15-08 Sheet: 10.1b |
| Office No. 972-219-3490 Fax No. 972-219-3487 www.cityoflewisville.com | |