


12" Meter Vault Parts

Item	Vendor	Part Number
Endress + Hauser Time Transit Meter 12"	Pantech Controls	93C3H-LHLC2AACBAAC
Eurtherm Chessel Chart Recorder, 4 Channel	Pantech Controls	392
Enclosure:M30 base mount NEMA cabinet	NAZTEC Inc. or Bison Mfg.	M30
Motorola ACE 3600 RTU	Automated Computer Systems	RTU
Antenna matched to radio frequency	Automated Computer Systems	ANT
Antenna cable and connector's	Automated Computer Systems	CAB1
Polyphaser surge protector	Automated Computer Systems	SUGE
Asbuilt drawings and O&M manuals	Automated Computer Systems	INST1
Operator Training	Automated Computer Systems	DV2
Startup and testing	Automated Computer Systems	PRGRTU
ROMAC Industries Dismantling Joint 12 in.	Ferguson Waterworks	STARTUO
Muller Resilient-Wedge Gate Valve Flange x MJ 12 in. (2 per Site)	Ferguson Waterworks	SP-DJ40512
Bolt and Gasket Set 12" (2 per site)	Ferguson Waterworks	MA23601912OL
Muller Swing type gravity operated check valve FL x FL 12 in	Ferguson Waterworks	FBGSETZ12
Dayton Sump Pump,submersible,cast iron	Grainger	SP-MA26000612
Standon Pipe Saddle Support Flange 12 in (2 per site)	Ferguson Waterworks	3BB80
Standon Pipe Saddle Support Pipe 12 in (1 per site)	Ferguson Waterworks	SP-MS8912
TESCO Service Pedestal	TESCO Controls Inc	SP-SS9212
Vault Access Doors 12 in meter U.S.F. Fabrication 48"x72"	Ferguson Waterworks	26-000
Link-Seal Modular sealing system for 12 in meter vault ( 2 per site)	Ferguson Waterworks	SP-BJDAL4872
Ductile iron pipe 12" by 36" flanged spool (meter outflow)	Municipal Water Works	SP-LCS1816/SP-LCS575C
Pressure Transmitter 1/4 NPT	Grainger	2HLT1 x 1/4 NPT
Check Valve 2" (Sump Pump)	Lowes / Home Depot	2" Check 5x5
HESCO Mainline input & Filter		

NOTE:  
 DETAIL SUBJECT TO CHANGE PER DIRECTION  
 OF CITY OF LEWISVILLE ENGINEERING DIVISION



Standard Details

Castle Hills  
 12" Meter Parts

Revisions:

No.	Description	Date

Engineering  
 Department

Office No. 972-219-3490

www.cityoflewisville.com

Dated: 5-14-13

Dated: 10-29-19

Sheet:

10.3d