



WIDTH: NORMAL TRENCH WIDTH
 LENGTH: PER THRUST BLOCK DETAIL

NOTE:

A PERMANENTLY ATTACHED VALVE EXTENSION STEM SHALL BE REQUIRED FOR ANY VALVE WHERE THE OPERATING NUT IS LOCATED IN EXCESS OF 48" BELOW FINISH GRADE. THIS EXTENSION SHALL BE OF SUFFICIENT LENGTH TO INSURE THAT THE OPERATING NUT IS WITHIN 48" OF THE VALVE BOX LID (FINISH GRADE)

VALVE BOX COVER, SECTIONS AND BASE TO BE MUELLER OR APPROVED EQUAL.

NOTE:
 DETAIL SUBJECT TO CHANGE PER DIRECTION OF CITY OF LEWISVILLE ENGINEERING DIVISION



Standard Details
 Valve Blocking &
 Adjustable Valve Box Detail

Revisions:		
No.	Description	Date

Engineering Department
 Office No. 972-219-3490
 www.cityoflewisville.com

Dated: 11-1-13
 Dated: 09-11-1029
 Sheet: 8.9