



ALL NEW CONNECTIONS AT EXISTING MANHOLES SHALL BE BY CORING ONLY

USE RAM-NECK O-RING, OR APPROVED EQUAL IN JOINTS

NOTE:  
MANHOLES WITH LINES ENTERING OR EXITING 12" OR LARGER REQUIRE 125 MIL RAVIN LINES

\* MANHOLE NOTES

- MANHOLE NOTES:
1. ALL SANITARY SEWER MANHOLES FOR SEWERS LARGER THAN 12" DIA. SHALL BE SPRAYED WITH THE FOLLOWING CORROSION RESISTANT COATING: RAVEN 408-100% SOLIDS/SOLVENT FREE ULTRA-HIGH-BUILD EPOXY SYSTEM FROM RAVEN LINING SYSTEMS WITH A MINIMUM THICKNESS OF 125 MILS.
  2. ALL MANHOLES SHALL BE PRECAST NO CAST-IN-PLACE MANHOLES WILL BE ACCEPTED.

PRECAST MANHOLE  
FLAT TOP

NOTE:  
DETAIL SUBJECT TO CHANGE PER DIRECTION OF CITY OF LEWISVILLE ENGINEERING DIVISION.

Revisions:

No.	Description	Date

Standard Details  
Precast Manhole  
Flat Top

Engineering Department

Office No. 972-219-3490

www.cityoflewisville.com

Dated: 4-27-10

Dated: 09-04-2019

Sheet:

7.1

