



No Coupling allowed on new installation.  
Service line must be solid piping.

Any break or extension in the service line will be connected with a brass comp by comp. coupling

NOTE:  
DETAIL SUBJECT TO CHANGE PER DIRECTION  
OF CITY OF LEWISVILLE ENGINEERING DIVISION



Standard Details

Typical Installation of Residential Water Meter

Revisions:		
No.	Description	Date

Engineering Department

Office No. 972-219-3490

www.cityoflewisville.com

Dated: 7-27-15

Dated: 10-24-19

Sheet: 8.19a